

NDSH

SOIL EVALUATION REPORT

in accordance with Comm 85, Wis. Adm. Code

Attach complete site plan on paper not less than 8 1/2 x 11 inches in size. Plan must include, but not limited to: vertical and horizontal reference point (BM), direction and Percent slope, scale or dimensions, north arrow, and location and distance to nearest road.

Please print all information.



Personal information you provide may be used for secondary purposes (Privacy Law, s. 15.04 (1) (m)).

County: Washington County	
Parcel I.D.:	
Reviewed by: <i>[Signature]</i>	Date: 12/20/04

Property Owner: JBJ Development		Property Location: Govt. Lot SE 1/4 NE 1/4 S 31 T 9 N - R 19 E (or) W	
Property Owner's Mailing Address: W176 N9912 Rivercrest Drive		Lot # 20 21	Block # Subd. Name or CSM # Cosgrove Acres
City: Germantown	State: WI	Zip Code: 53022	Phone Number: ( ) -
<input type="checkbox"/> City: <input type="checkbox"/> Village: <input checked="" type="checkbox"/> Town:		Nearest Road: Palomino Court	

<input checked="" type="checkbox"/> New Construction	Use <input checked="" type="checkbox"/> Residential / Number of bedrooms: 4	Code derived design flow rate: 600 GPD
<input type="checkbox"/> Replacement	<input type="checkbox"/> Public or commercial - Describe:	
Parent material: Loess over glacial outwash		Flood Plain elevation if applicable: n/a ft.
General comments and recommendations: Conventional type system		

1 Boring #  Boring  Pit Ground surface elev. 1060.39 ft. Depth to limiting factor >156 in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft <sup>2</sup>	
									Eff#1	Eff#2
Ap	0-10	10 YR 4/2		SiCL	2 m gr	mfr	as	2f-1m	.4	.6
Bt1	10-18	10 YR 4/4		CL	2 m-co abk	mfi	cs	2f-1m	.4	.6
2Bt2	18-36	10 YR 3/4		gr CL	2 m abk	mfi	gw	2f-1m	.4	.6
2C	36-156	10 YR 6/4		vgr-cb CoS	0sg	ml	--	1f	.7	1.6

2 Boring #  Boring  Pit Ground surface elev. 1064.25 ft. Depth to limiting factor >108 in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft <sup>2</sup>	
									Eff#1	Eff#2
Ap	0-11	10 YR 4/2		SiL	2 m gr	mfr	as	2f-2m	.5	.8
Bt1	11-24	10 YR 5/4		SiCL	2 m sbk	mfi	cs	2f-1m	.4	.6
Bt2	24-39	10 YR 4/4		CL	2 m-co abk	mfi	dw	2f-1m	.4	.6
2BC	39-52	10 YR 3/4		SL	2 m sbk	mfr	gw	1f	.5	.8
2C	52-108	10 YR 6/4		vgr-cb CoS	0 sg	ml	--	--	.7	1.6

\* Effluent # 1 = BOD<sub>5</sub> > 30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L

\* Effluent # 2 = BOD<sub>5</sub> ≤ 30 mg/L and TSS ≤ 30 mg/L

CST Name (Please Print): David LaBott	Signature: <i>[Signature]</i>	CST Number: 71449
Address: 55 S. Third Ave. Sturgeon Bay, WI 54235		Telephone Number: ( 920 ) 743 - 8211
Date Evaluation Conducted: 5-6-03		

**3** Boring #  Boring  Pit Ground surface elev. 1063.89 ft. Depth to limiting factor >120 in Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft <sup>2</sup>	
									Eff#1	Eff#2
Ap	0-9	10 YR 4/2		SiL	2 m gr	mfr	as	2f-2m	.5	.8
Bt1	9-14	10 YR 5/4		SiCL	2 m sbk	mfi	cs	2f-1m	.4	.6
Bt2	14-21	10 YR 4/4		CL	2 m-co abk	mfi	dw	2f-1m	.4	.6
2Bt3	21-38	10 YR 3/4		gr CL	2 m co sbk	mfi	gw	1f	.4	.6
2C	38-120	10 YR 6/4		vgr-cb CoS	0 sg	ml	--	--	.7	1.6

**4** Boring #  Boring  Pit Ground surface elev. ft. Depth to limiting factor in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft <sup>2</sup>	
									Eff#1	Eff#2

**5** Boring #  Boring  Pit Ground surface elev. ft. Depth to limiting factor in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft <sup>2</sup>	
									Eff#1	Eff#2

\* Effluent # 1 = BOD<sub>5</sub>>30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L

\* Effluent # 2 = BOD<sub>5</sub>≤ 30 mg/L and TSS ≤ 30 mg/L

The Department of Commerce is an equal opportunity service provider and employer. If you need assistance to access services or need material in an alternate format, please contact the department at 608-266-3151 or TTY 608-264-8777.



NORTH  
1" = 50'

# SITE PLAN

## COSGROVE ACRES

LOT ~~20~~ 21

SE 1/4 OF THE NE 1/4, SEC. 31, T. 9 N., R. 19 E.,  
TOWN OF RICHFIELD, WASHINGTON COUNTY,  
WISCONSIN.

PREPARED FOR:  
JBJ DEVELOPMENT  
W178 N9912 RIVERCREST DR.  
GERMANTOWN, WI  
53022

PREPARED BY:  
BAUDHUIN INCORPORATED  
55 S. 3RD AVENUE  
P.O. BOX 105  
STURGEON BAY, WI 54235

SOILS BY: DAVID LABOTT  
DRAWN BY: DAVID LABOTT  
CST. MPRS #71449

NOTE:  
BENCHMARKS TO BE SET AND MAPS REVISED  
ONCE THE ROAD IS CONSTRUCTED.

