

in accordance with Comm 85, Wis. Adm. Code

Attach complete site plan on paper not less than 8 1/2 x 11 inches in size. Plan must include, but not limited to: vertical and horizontal reference point (BM), direction and Percent slope, scale or dimensions, north arrow, and location and distance to nearest road.

Please print all information.

Personal information you provide may be used for secondary purposes (Privacy Law, s. 15.04 (1) (m)).

County:
WASHINGTON

Parcel I.D.:

Reviewed by:

JS

Date:

12/14/22

Property Owner: JBJ DEVELOPMENT		Property Location: Govt. Lot 1/4 1/4 S 20 T 9 N - R 19 E (or) W			
Property Owner's Mailing Address: W178 N9912 RIVERCREST DRIVE		Lot # 17 5	Block #	Subd. Name or CSM # THE OAKS	
City: GERMANTOWN	State: WI	Zip Code: 54204	Phone Number: () -	☐ City: ☐ Village: ☒ Town: RICHFIELD	Nearest Road: HIGHRIDGE COURT
☒ New Construction		Use ☒ Residential / Number of bedrooms: 4		Code derived design flow rate: 600 GPD	
☐ Replacement		☐ Public or commercial - Describe:			
Parent material: GLACIAL TILL				Flood Plain elevation if applicable: N/A ft.	
General comments and recommendations: Suitable for a at-grade system					

Revisions per 1/21/24 pre plat

1	Boring #	☐ Boring	☒ Pit	Ground surface elev. 1145.9 ft.	Depth to limiting factor 37 in.	Soil Application Rate				
Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
Ap	0-8	10 YR 3/2		SiL	2 f-m gr	mvfr	as	3f-1m	.6	.8
Bt1	8-24	10 YR 4/4		CL	2 m abk	mfi	cs	2f	.4	.6
2Bt2	24-37	10 YR 3/4-4		gr CL	2 f-m abk	mfi	gw	1vf	.4	.6
2C	37-60	10 YR 6/3	c2d 10 YR 5/8	gr SL	1 f abk	mfr	--	--	.4	.6

2	Boring #	☐ Boring	☒ Pit	Ground surface elev. 1148.2 ft.	Depth to limiting factor 47 in.	Soil Application Rate				
Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
Ap	0-9	10 YR 4/2		SiL	2 f-m gr	mvfr	as	3f-1m	.6	.8
Ab	9-21	10 YR 3/2		SiL	2 m abk	mfi	cs	2f	.6	.8
Bt1	21-34	10 YR 5-4/4		SiCL	2 f-m abk	mfi	cw	1f	.4	.6
Bt2	34-47	10 YR 4/4	3/4 clay skins	CL	2 f abk	mfi	cs	--	.4	.6
Bt3	47-54	10 YR 4/4	flf 10 YR 5/8	CL	2 f-m abk	mfi	-	--	.4	.6

* Effluent # 1 = BOD₅ > 30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L* Effluent # 2 = BOD₅ ≤ 30 mg/L and TSS ≤ 30 mg/L

CST Name (Please Print): David B. LaBott(Baudhuin Inc.)	Signature: 	CST Number: 71449
Address: 55 South Third Ave. Sturgeon Bay, WI 54235	Date Evaluation Conducted: 11-24-03 & 4-28-04	Telephone Number: (920) 743 - 8211

Property Owner:

Parcel ID #: LOT 17/5

Page 2 of 3

3 Boring # ☐ Boring ☒ Pit Ground surface elev. 1144.2 ft. Depth to limiting factor 39 in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-9	10 YR 3/2		SiL	2 f-m gr	mvfr	as	3f-1m	.6	.8
Bt1	9-18	10 YR 5/4-4		SiCL	2 m abk	mfi	cs	2f	.4	.6
Bt2	18-26	10 YR 4/4		CL	2m-co abk	mfi	cs	--	.4	.6
2Bt3	26-39	10 YR 3/4		gr CL	2 f abk	mfi	gw	--	.4	.6
2C	39-60	10 YR 6/2-3	c2d 10 YR 5/8	gr L	0m	mfr	--	--	.2	.5

4 Boring # ☐ Boring ☒ Pit Ground surface elev. 1136.0 ft. Depth to limiting factor 39 in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-7	10 YR 3/2		SiL	2 f-m gr	mvfr	as	3f-1m	.6	.8
2Bt1	7-16	10 YR 4/4		gr CL	2 m abk	mfi	cs	2f	.4	.6
2BC	16-39	10 YR 5/4		gr SL	2 f-m abk	mfr	gw	1vf	.6	1.0
2C	39-60	10 YR 6/3	flf 10 YR 5/8	gr L	1 f abk	mfr	--	--	.4	.6

5 Boring # ☐ Boring ☒ Pit Ground surface elev. 1144.0 ft. Depth to limiting factor 39 in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-9	10 YR 3/2		SiL	2 f-m gr	mvfr	as	3f-1m	.6	.8
Bt1	9-16	10 YR 5/4-4		SiCL	2 m abk	mfi	cs	2f	.4	.6
Bt2	16-27	10 YR 4/4		CL	2m-co abk	mfi	cs	--	.4	.6
2Bt3	27-39	10 YR 3/4		gr CL	2 f abk	mfi	gw	--	.4	.6
2C	39-60	10 YR 6/2-3	c2d 10 YR 5/8	gr L	0m	mfr	--	--	.2	.5

* Effluent # 1 = BOD₅ > 30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L* Effluent # 2 = BOD₅ ≤ 30 mg/L and TSS ≤ 30 mg/L

The Department of Commerce is an equal opportunity service provider and employer. If you need assistance to access services or need material in an alternate format, please contact the department at 608-266-3151 or TTY 608-264-8777.




SITE PLAN THE OAKS

SECTION 20 T.9 N., R.9 E.
TOWN OF RICHFIELD, WASHINGTON COUNTY

PREPARED FOR:
JBJ DEVELOPMENT:
W178 N9912 RIVERCREST DR
GERMANTOWN, WI
53022

*** BENCHMARKS TO BE SET AFTER
CONSTRUCTION OF OAKLEAF HIGHRIDGE
COURT. SITE PLAN TO BE REVISED AND
RESUBMITTED TO THE COUNTY



SOIL EVALUATION LOT 17 5	THE OAKS	Baudhuin Incorporated engineers • architects • interior designers	P.O. BOX 105 55 S. 3RD AVENUE STURGEON BAY, WI. 54235 FAX: 920-743-8217 PHONE: 1-800-773-8211 PHONE: 920-743-8211	REUSE OF DOCUMENTS THIS DOCUMENT HAS BEEN DEVELOPED FOR A SPECIFIC APPLICATION AND NOT FOR GENERAL USE. THEREFORE IT MAY NOT BE USED WITHOUT THE WRITTEN APPROVAL OF BAUDHUIN INCORPORATED. UNAPPROVED USE IS THE SOLE RESPONSIBILITY OF THE UNAUTHORIZED USER. Y:\MGM\LDWG\SCHMITT-BENCE\DWG\714-SL.DWG	DATE: 5/20/04 DESIGNED BY: D.B.L. DRAWN BY: D.J.D.
-----------------------------	-----------------	--	--	--	---