

Parcel I.D.:

Reviewed by:

Date:

Personal information you provide may be used for secondary purposes (Privacy Law, s. 15.04 (1) (m)).

Property Location: ☒ ☐
Govt. Lot $\frac{1}{4}$ $\frac{1}{4}$ S 20 T 9 N - R 19 E (or) W

Lot # 9 50	Block #	Subd. Name or CSM # THE OAKS
---------------	---------	---------------------------------

☐ City: ☐ Village: ☒ Town:
RICHFIELD

Nearest Road:
~~GREEN OAKS DRIVE~~
OLIVER'S DRIVE

Code derived design flow rate:	600	GPD
--------------------------------	-----	-----

☐ Public or commercial – Describe:

Flood Plain elevation if applicable: N/A ft.

General comments and recommendations: Suitable for An at-grade system

Revisions per 1/21/24 pre plat

1

☐ Boring

☒ Pit Ground surface elev. 1107.8 ft.

Depth to limiting factor 36 in.

Soil Application Rate

2☐ Boring

☒ Pit Ground surface elev. 1104.1 ft.

Depth to limiting factor ~~39~~ in.

Soil Application

* Effluent # 1 = $\text{BOD}_5 > 30 \leq 220 \text{ mg/L}$ and $\text{TSS} > 30 \leq 150 \text{ mg/L}$

* Effluent # 2 = $\text{BOD}_5 \leq 30 \text{ mg/L}$ and $\text{TSS} \leq 30 \text{ mg/L}$

Signature: _____

CST Number:
71449

Date Evaluation Conducted:
11-24-03 & 4-28-04

Telephone Number:
(920) 743 - 8211

Property Owner:

Parcel ID #: LOT ~~8~~ 50

Page 2 of 3

3 Boring # ☐ Boring ☒ Pit Ground surface elev. 1104.9 ft. Depth to limiting factor 45 in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-12	10 YR 4/2		SiL	2 f-m gr	mvfr	as	3f-1m	.6	.8
Bt1	12-21	10 YR 4/4		CL	2 m abk	mfi	cs	2f	.4	.6
2Bt2	21-31	10 YR 4/4		grCL	2 f-m abk	mfi	cw	1f	.4	.6
2BC	31-45	10 YR 6/4		gr SL	1 f abk	mfr	gw	--	.4	.7
2C	45-60	10 YR 6/3	c2d 10 YR 5/8	gr L	0m	mfr	--	--	.2	.5

4 Boring # ☐ Boring ☐ Pit Ground surface elev. ft. Depth to limiting factor in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2

5 Boring # ☐ Boring ☐ Pit Ground surface elev. ft. Depth to limiting factor in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2

* Effluent # 1 = BOD₅>30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L* Effluent # 2 = BOD₅≤ 30 mg/L and TSS ≤ 30 mg/L

The Department of Commerce is an equal opportunity service provider and employer. If you need assistance to access services or need material in an alternate format, please contact the department at 608-266-3151 or TTY 608-264-8777.



SITE PLAN THE OAKS

SECTION 20 T.9 N., R.9 E.
TOWN OF RICHFIELD, WASHINGTON COUNTY

PREPARED FOR:
JBJ DEVELOPMENT:
W178 N9912 RIVERCREST DR
GERMANTOWN, WI
53022

*** BENCHMARKS TO BE SET AFTER
CONSTRUCTION OF OAKLEAF HIGHRIDGE
COURT. SITE PLAN TO BE REVISED AND
RESUBMITTED TO THE COUNTY

